

**SECTION 610
CARBON MONOXIDE ALARMS**

610.3.1 ONE-FAMILY DWELLINGS

610.3.1 Buildings constructed on or after January 1, 2008.

610.3.1.1 A Carbon monoxide alarm shall be provided on each story containing a sleeping area, within 15 feet of the sleeping area. More than one carbon monoxide alarm shall be provided where necessary to assure that no sleeping area on such story is more than 15 feet away from a carbon monoxide alarm.

610.3.1.1.2 A carbon monoxide alarm shall be provided on each story that contains a carbon monoxide source.

610.3.1.2 Buildings constructed prior to January 1, 2008. A carbon monoxide alarm shall be provided on the lowest story containing a sleeping area, within 15 feet of the sleeping area. More than one carbon monoxide alarm shall be provided where necessary to assure that no sleeping area on such story is more than 15 feet away from a carbon monoxide alarm.

NOTE: All carbon monoxide detectors and smoke alarms must be tied into each other.

- **Please see Code Officer for all other types of construction**